

Fri 3/8/2024 12:50 PM

To:Lynne Bermudez;Ray Chesley;Heidi Gaffney
Cc:Sue Winslow

Lynne,

The Village Shopping Center has a common septic system that serves the proposed dance studio space and all of the tenants within the center (except Gils Grocery). It will be necessary for the applicant to have a Professional Engineer or Registered Sanitarian produce a letter/analysis documenting the septic design flow for the proposed dance studio. The letter should establish that the septic flow from the proposed studio will not exceed the capacity of the common septic system based on the current uses within the shopping center. Please have the applicants contact me if they have any questions. Thank you.

Gerry McDonald
Topsfield Health Director